

# LANCASTER COUNTY

COUNTY-CITY BUILDING Telephone: (402) 441-7410  
LINCOLN, NEBRASKA 68508 FAX : (402) 441-6513  
*BOARD OF COMMISSIONERS*

## **ADDENDUM #4**

**Issue Date: 11/14/05**

### **SPECIFICATION NO. 05-281**

**FOR**

### **CONSTRUCTION OF COMMUNICATIONS TOWER & PRE-FABRICATED BLDG.**

Addenda (or addendum if singular) are written instruments issued by the County prior to the date for receipt of offers which will modify or interpret the specification document by addition, deletion, clarification or correction. Please acknowledge receipt of this addendum in the space provided on your bidding document.

Be advised of the following changes to the County's specification and bidding documents:

1. ADD CHANGE: Because the grounding system for our tower site will be bonded to the grounding system of Lincoln Electric System's (LES) Substation, the engineers at LES have decided that we need to extend our grounding system 3-feet outside of our fence. This addition to our ground grid will help protect an individual should a major fault occur within LES's substation while an individual is in contact with our fence.
  - 1.1 There is no change in the wording of Section 1 – Site Development.
  - 1.2 Revised Figure 1 (Page 18) and Figure 2 (Page 19) are included in cad file associated with this addendum

All other terms, conditions and requirements of the request remain the same as originally indicated in the document or as modified on previous addenda.

Kathy A. Smith  
Assistant Purchasing Agent

F:\FILES\SHARPURC\Spec.05\05-281 addendum 4.wpd

---

#### COMMISSIONERS

DEB SCHORR \* LARRY HUDKINS \* RAY STEVENS \* BERNIE HEIER \* BOB WORKMAN  
KERRY EAGAN, Chief Administrative Officer



